

FILTER MEDIA DATA

SEW 166Alu FR is a 100% Flame retardant Aluminium coated spun bond Bi-Co filters media that is manufactures from continuous fibre who does not permit the particles to become embedded.

SEW 166 Alu FR is very rugged and have a high burststrength that make it resistant to abrasion, water,heat and chemicals.

100 % Spun bond media with a unique shaped bonding that makes pulse cleaning easier and are running with lower pressure drop SEW 166 Alu FR is a washable filter media.

Chemical Resistance | Chemische Eigenschaften

	Excellent Sehr Gut	Good Gut	Fair Mässig
Dil/water resistance DI und Wasserabweisend	Х	X	X
lydrolysis resistance ydrolysebeständigkeit	X	X	X
cid resistance äurebeständigkeit	X	X	X
Alkaline resistance Alkalienbeständigkeit	X	X	X

W Filtration A/S

Phone +45 5460 2080

S.E.W. North Filtration A/S * Vesterbrogade1, Section C * DK-4930 Maribo E-mail: sales@northfiltration.com * www.northfiltration.com * VAT no.: DK 33 49 28 71





test report

Page 1 of 3

Type Test according DIN EN 60335-2-69:2015

BLANKENBERG - MEßTECHNIK / DATENVERARBEITUNG

Oderstr. 2, D-47506 NEUKIRCHEN-VLUYN, Tel.: +49 02845 58303, Fax: +49 02845 58461, E-Mail: Labor@Blankenberg-mt.org

customer :	S.E.W. North Filtration A/S	Date : 07.09.2019					
	Vesterbrogade 1, Sektion C	Date of order : 30.08.2019					
	4930 - Maribo	Entering of the sample .03.09.2019					
Order :	Type testing of a filter material on a test rig accor with a air permeability of 200 m³/(m²*h) or a face						
Remarks on the order :	The test result is based explicitly only on the DIN AA.22.201.1. Another statements on the specime						
Kind of sampling:	15 samples of the filter material with dimensions sent with date of the 09/03/2019 to the testlabora						
Test Device :	SEW166 ALU-FR / Polyester Spinnvlies a	ntistatisch und flammhemmend					
Test results :	Dust class **) : M (D: < 0,07	67 %)					
Test air flow rate	200 m³/(m²*h) / 0,056 m/s						
initial pressure drop : for test dust (Quarze	56 Pa max. final pres staub) for	ssure drop : 243 Pa Test aerosol()					
initial arrestance :	> 99,9233 % initial arrestance ***)	. /					
Average dust weight :	initial fraction arrestar	nce ***):					
Air permebility : 200 F	a of 675,48 m³/(m²*h) inatial specific test arr	estance *):					
Dust class M. When testing viation of 0.00248 mean tra value = 0.0792%, minimum If the air permeability is inc the dust class M is retained							
valid for identical types. Th in its original form and cont sation. A part of the test rep agreement of the testing of	mbination with the test device and are only e test report can only be made public or copied ent, with the agreement of the testing organi- port may only made public with the testing fice.	Supervisor					
***) : The test-rusults are based on an itegrated and continuous neutralization as well as freight-control of the test dust, aerosol or test device. *) : Test Rusults acording to ASHRAE 52 76 or BS 3928 / 4400 (Sodium - Flame - Test)							
Report No. TU0022F2006287	6 Date of test 11.09.2019 Vali	d of test report until: 11.09.2021					



Test object

Page 2 of 3

Type Test according DIN EN 60335-2-69:2015

BLANKENBERG - MEßTECHNIK / DATENVERARBEITUNG

Oderstr. 2 , D-47506 NEUKIRCHEN-VLUYN , Tel.: +49 02845 58303 , Fax : +49 02845 58461 , E-Mail : Labor@Blankenberg-mt.org

nanufacturer or r customer :	S.E.W. North Filtration A			
	Vesterbrogade 1, Sektion C			
	4930 - Maribo			
evice description accor	rding to manufacturer or	costumer		
Device name :	SEW166 ALU-FR	Design model Nr. :	Polyester Spinnvlies antistati sch und flammhemmend	
Configuration :		Device filter media :	syntetic	
effective filter area : Weight :	100 cm² 257,78 g/m²	face dimension : thickness :	450 mm x 450 mm 0,72 mm	
roposers recommended	d operating data		JAC-	
Nominal air flow rate :	200 m³/(m²*h)		V V	
Comporaturo resistanco :		Burst pressure :		
Γemperature resistance : nitial pressure drop :	 55 Pa	final pressure drop :		
evice description				
		C/N r		
		\mathcal{O}	5	

Date of test 11.09.2019

8

Valid of test report until: 11.09.2021



initial pressure drop

Page 3 of 3

Type Test according DIN EN 60335-2-69:2015

BLANKENBERG - MEßTECHNIK / DATENVERARBEITUNG

Oderstr. 2 , D-47506 NEUKIRCHEN-VLUYN , Tel.: +49 02845 58303 , Fax : +49 02845 58461 , E-Mail : Labor@Blankenberg-mt.org





Notes to the certificate Type Test according DIN EN 60335-2-69:2015

BLANKENBERG - MEßTECHNIK / DATENVERARBEITUNG

Oderstr. 2 , D-47506 NEUKIRCHEN-VLUYN , Tel.: +49 02845 58303 , Fax : +49 02845 58461 , E-Mail : Labor@Blankenberg-mt.org

The test results are based on one single and/or small series test and are valid only for Identical types. For an evaluation, one must consider that the measuring tolerances of the testing method are always withhin the tolerances accepted for this testing method, also under consideration of the material and fabrication tolerances according during fabrication.

Evaluation of the test results

The test results, shown in the certificate, are only related to the operating data and the test procedures, which are required by the manufacturer. They consider the following criteria.

1.1. The pressure loss resp. Inital - or final pressure loss

1.2. The arrestance grade (depending on the test procedure, different norminations are usual)

- inital- and average dust spot effiency,
- inital- and average dust weight arrestance,
- transmission factor,
- fraction arrestance

1.3. Dust holding capacity

Due to a dust feeding, there will be a charge of the pressure loss and the arrestance grade of the air filter.

1.4. Air filter - classification

The classification of the air filter refers exclusively of the criteria based on each test norm. (e.g. arrestance or classification - pressure loss).

2. Comparison of the test results

Valuation and comparison of filter - test results assume that only those filters can be compared whose results are at least tested under the same conditions like (e.g. up to a comparable pressure loss or at the same air flow rate)

In case the conditions are not identical or the test results are based on different test methods, these data are limited or not compartible.

Indications regarding the dust holding capacity are only valid on basis of the test conditions. Inside the validity of a test report, there can be completely different conditions, depending on the test laboratory's and / or manufacturer's requirements. Are there no single - test certificats for the mentioned comparison - final pressure difference avoi et lable, one can calculate them, under the condition of a sufficient accuracy from the test certificates and / or graphically from the curves.